

- g. However, during evening peak hours, the quota will be five percent of the quota fixed for demand and energy for HT industrial services, and ten percent of the quota fixed for demand and energy for commercial consumers, for essential lightning and security purposes.
- h. In case of reduction of sanctioned demand permitted after September 2008, the demand quota permitted shall not exceed 60% of the sanctioned demand after reduction.
- i. For additional load to existing HT service availed on or after 01.10.2008, their additional demand quota shall be fixed as 40% of the sanctioned demand and the additional consumption quota shall be 200 units per KVA for the load additionally sanctioned.
- j. The unutilized quota in any quota period will not be carried over to the subsequent period. Transfer of quota from a service which is under strike, lock-out, lay off and sick is not permissible.
- k. There shall be no demand and energy cut for HT services in rural feeders since they are coming under single phase arrangement.
- l. For HT services in rural feeder which are provided with fourth wire, demand and energy quota has to be fixed.
- m. All HT industrial and commercial services for which power supply has been given on or after 01.10.2008 shall be deemed as new service and the demand quota shall be fixed as 40% of the sanctioned demand and energy quota will be fixed at 200 units/KVA.
- n. In the case of continuous process industries and those HT services which cannot operate with the present level of cut, the Chief Engineer/ distribution concerned can fix such optimum/minimum demand as may be required to operate the industry, but this will be subject to the power supply being made available only for such restricted specified period depending upon the nature of process of the industry so as to keep with the overall capability of the grid.

Example :-

Sanctioned demand	2200 KVA
Recorded maximum demand	2000 KVA
Base quota fixed @ 60 %	1200 KVA